



Fort Valley State University: Miller Hall Fort Valley State University: Miller Hall






Campus Map



Mid-20th Century Buildings Workshop






Miller Hall



Site Plan Ohio Hall





Main Floor Plan













Mid-20th Century Buildings Workshop

Fort Valley State University: Miller Hall Miller Hall Energy Study





Miller Hall Energy Study Fort Valley State University

BOR Project Number J-155

Board of Regents of the University System of Georgia

In conjunction with:
Georgia Environmental Facilities Authority

Prepared by: Surber Barber Choate & Hertlein Architects, P.C.

> with: Essex Engineering Corporation SL King and Associates, Inc. Costing Services Group iLight Studio

> > June 23, 2010



This study was funded by the American Recovery and Reinvestment Act through the US Department of Energy's State Energy Program. These funds were coordinated and administered in cooperation with the Georgia Environmental Facilities Authority.

Miller Hall Energy Study

TABLE OF CONTENTS

Acknowledgements

Executive Summary

Miller Hall Background and The Impetus for the Energy Study

Miller Hall Photos

Miller Hall Floor Plans

Methodology

Energy Modeling Scenarios

Recommendations

Appendix:

Table 1 Comparison of Current Building, Proposed Building and Further Energy Conservation Opportunities

Table 2 Payback and Energy saved per investment for Each Energy Conservation Opportunity

Thermography Photographs

Cost Estimates

Resources

Miller Hall Energy Study



Mid-20th Century Buildings Workshop





Typical Window

Window Sill



Table 1. Comparison of Current Building, Proposed building and Further Energy Conservation Opportunites.

Project Run	ECO Description	Electricity		Natural Gas		Total Energy		Total Yearly Cost	
		Usage (x1,000) kWh	Savings	Usage (x1,000,000) Btu	Savings	Usage (x1,000,000) Btu	Savings	Cost (\$)	Savings
Current Building		515.3		648.1		2406.8		\$66,781	
Baseline	renovation baseline	401.9		928.46		2300.1	4.4%	\$54,210	18.8%
Reduced Lighting	F28T8 vs F32T8	385.5	4.1%	933.5	-0.5%	2249.2	2.2%	\$52,233	3.6%
R30 Roof	R30 roof insulation	402.7	-0.2%	925.09	0.4%	2297.4	0.1%	\$54,222	0.0%
PVC Roof	PVC membrane on 2- inch It wt concrete	399.36	0.6%	966.66	-4.1%	2330	-1.3%	\$54,014	0.4%
Operable Windows	Keep operable windows	400.61	0.3%	971.83	-4.7%	2339.1	-1.7%	\$54,183	0.0%
Insulating Glass	insul glass in current window frame	402.18	-0.1%	897.41	3.3%	2270	1.3%	\$54,154	0.1%
Aluminum Frame	New alu frame window	401.5	0.1%	886.99	4.5%	2257	1.9%	\$54,042	0.3%
Vinyl Frame	New vinyl frame window	401.52	0.1%	882.99	4.9%	2253.4	2.0%	\$54,033	0.3%
Daylighting	Daylighting Controls	385.69	4.0%	932.66	-0.5%	2249	2.2%	\$52,253	3.6%
VAV	VAV HVAC System	526.04	-30.9%	68.77	92.6%	1864.1	19.0%	\$66,708	-23.1%
DCV*	DCV estimate					2242.6	2.5%		
VRFZ*	Estimate of VRFZ system instead of 4-pipe HVAC system.					2019.12	12.2%		

^{*}savings for these ECO are estimates only, as they could not be accurately modeled in eQUEST

Comparison of Existing Building to Proposed Work



Mid-20th Century Buildings Workshop

Table 2. Payback and Energy Saved per Investment for each Energy Conservation Opportunity

Project Run	ECO Description	Total Energy		Total Yearly Cost		Installation Cost	Payback	Energy Saved per Investment (MBtu/ 1,000	
		Usage (x1,000,000) Btu	Savings	Cost (\$)	Savings	installation Cost	(years)	dollars)	
Current Building		2406.8		\$66,781					
Baseline	renovation baseline	2300.1	4.4%	\$54,210	18.8%				
Reduced Lighting	F28T8 vs F32T8	2249.2	2.2%	\$52,233	3.6%	\$20,499	10.5	2.5	
R30 Roof	R30 roof insulation	2297.4	0.1%	\$54,222	0.0%	\$31,706	none	0.1	
PVC Roof	PVC membrane on 2- inch It wt concrete	2330	-1.3%	\$54,014	0.4%	Not Price			
Operable Windows	Keep operable windows	2339.1	-1.7%	\$54,183	0.0%	\$0	0.0		
Insulating Glass	insul glass in current window frame	2270	1.3%	\$54,154	0.1%	\$131,381	none	0.2	
Aluminum Frame	New alu frame window	2257	1.9%	\$54,042	0.3%	\$164,226	none	0.3	
Vinyl Frame	New vinyl frame window	2253.4	2.0%	\$54,033	0.3%	\$65,690	none	0.7	
Daylighting	Daylighting Controls	2249	2.2%	\$52,253	3.6%	\$40,998	21.0	1.2	
VAV	VAV HVAC System	1864.1	19.0%	\$66,708	-23.1%	\$25,184	none	17.3	
DCV*	DCV estimate*	2242.6	2.5%			\$12,885		4.5	
VRFZ*	Estimate of VRFZ system instead of 4-pipe HVAC system.	2019.12	12.2%			\$126,748		2.2	


^{*}savings for these ECO are estimates only, as they could not be accurately modeled in eQUEST


Payback and Energy Saved



Fort Valley State University: Miller Hall Miller Hall: Programmatic Issues







Main Floor







Classrooms





Offices Public Spaces



Fort Valley State University: Miller Hall Miller Hall: Technical Challenges







Steel Structure with CMU Shear Walls; Low ceiling heights



Systems shared with adjacent buildings



Window and masonry rehabilitation



Fort Valley State University: Miller Hall Implementation



















Miller Hall \$150/square foot (estimated)

vs.

New Construction @ \$180-\$240/square foot





